

EU DECLARATION OF CONFORMITY – No CETF032 rev1

Manufacturer: Tunstall Healthcare (UK) Ltd
Whitley Lodge, Whitley Bridge
Yorkshire, DN14 0HR
UK
Tel: +44 1977 661234

This declaration is issued under the sole responsibility of the manufacturer.
The manufacturer declares under our own responsibility that the following radio product(s):

Product name:	Product number:	Product Description:
Optical 869 Smoke Alarm	68005/70	Ei650W Smoke Alarm (869MHz)

complies with the requirements of the following directive(s)

2014/53/EU Radio Equipment Directive (RED)
2011/65/EU Restriction of the use of certain hazardous substances (RoHS)


The conformity was checked in accordance with the following harmonised EN standard(s):

EN 300 220-3-1 V2.1.1 (2016-12) Radio standard for low duty-cycle high reliability equipment
EN 55032:2012: Electromagnetic compatibility of multimedia equipment. Emission Requirements
EN 50130-4: 2011 EMC Product Family Standard; Immunity Requirements for Components of Fire, Intruder and Social Alarm Systems

The smoke alarm complies with the following Fire Safety standard:
EN14604:2005+AC:2008

Signed

Date


Elaine Quinn

23/4/19

Position: Group Operations Director, Tunstall Healthcare (UK) Ltd